

City of Taunton - Cost Estimation for Parking Facilities

City Priorities

Priority 1: Program Access
Priority 2: Safety
Priority 3: Approach and Entrance
Priority 4: Access to Goods and Services
Priority 5: Toilet or Bathing Rooms
Priority 6: Additional Access

*Cost Estimate Notes:

- Cost of design is not included.
- Does not include costs when note indicates future work.
- Labor cannot be estimated for all remedies.
- There is no cost noted when it's presumed to be a maintenance issue.
Estimates are intended as a guide to budgeting access modifications and are not intended to be absolutely comprehensive or definitive.

Information Provided by Institute for Human Centered Design

Information Provided by City of Taunton

FACILITY	REFERENCE #	FO WORK ORDER #	ELEMENT	ISSUE / PHYSICAL BARRIER	LOCATION WITHIN FACILITY	CITY PRIORITY	PRIORITY FOR BARRIER REMOVAL	ACTION FOR BARRIER REMOVAL	ESTIMATED COST OF BARRIER REMOVAL	PROJECT START DATE	PROJECT COMPLETION DATE	RESPONSIBLE FOR BARRIER REMOVAL	BARRIER REMOVED	X
Court St.	P-101A		C. Accessible Route/Walkway	H.Ecross slope >1:48 G.Burning slope >1:20		Priority 3	Approach and Entrance	Correct the cross and run slopes adjoining the curb ramp.	\$6,000.00	2017	2018	Parking Commission	completed	
Court Street Parking Lot	P-013		D. Off-Street Parking Spaces	H.Ecross slope >1:48 G.Burning slope >1:20	parking lot	Priority 1	Program Access	corret croo slope	\$30,000.00	2019	2019	Parking Commission	completed	
Court Street Parking Lot	BB-060, P-001		B. Curb Ramp	A.Burning slope at curb ramp > 1:12 B.Ecross slope >1:48		Priority 3	Approach and Entrance	Correct slope and cross slope at curb ramp.	\$8,000.00	2017	2018	Parking Commission	completed	
Bay Street Parking Lot	P-002		D. Off-Street Parking Spaces	A.Total # of parking spaces B.Total # of designated accessible spaces C.Minimum number of spaces not provided D.Min space not provided N.Not in operable working condition	parking lot	Priority 1	Program Access	Provide one van-accessible space. Provide an access aisle. Provide parking identification sign.	\$870.00	2017		Parking Commission		
Galligan's Court Parking Lot	P-003		D. Off-Street Parking Spaces	A.Total # of parking spaces B.Total # of designated accessible spaces D.Min space not provided M.Min <60" above finished floor	Weir Street entrance	Priority 3	Approach and Entrance	Provide one van-accessible space. Provide marking at access aisle. Provide parking identification sign.	\$870.00	2017		Parking Commission		
Galligan's Court Parking Lot	P-004		D. Off-Street Parking Spaces	A.Total # of parking spaces B.Total # of designated accessible spaces J.Surface not stable, firm, and slip-resistant M.Min <60" above finished floor	entrance near Lincoln Street	Priority 3	Approach and Entrance	Provide one van-accessible space. Provide marking at access aisle. Provide parking identification sign.	\$870.00	2017		Parking Commission		
Galligan's Court Parking Lot	BB-0062		C. Accessible Route/Walkway	H.Ecross slope >1:48	entrance near Lincoln Street	Priority 3	Approach and Entrance	Correct cross slope at accessible route.		2017		Parking Commission		
Parking Deck	P-008		B. Curb Ramp	A.Burning slope at curb ramp > 1:12	near southeast stairwell	Priority 1	Program Access	Correct slope at curb ramp.	\$116.25	2016	May 16	Parking Commission	completed	
Parking Deck	P-005		D. Off-Street Parking Spaces	A.Total # of parking spaces B.Total # of designated accessible spaces D.Min space not provided	near southwest stairwell	Priority 1	Program Access	Provide 2 accessible parking spaces. Provide one van-designated space. Provide parking identification sign.	\$874.50	2016	May 16	Parking Commission	completed	
Parking Deck	P-006		D. Off-Street Parking Spaces	A.Total # of parking spaces B.Total # of designated accessible spaces D.Min space not provided	near southwest stairwell	Priority 1	Program Access	Provide 2 accessible parking spaces. Provide one van-designated space. Provide parking identification sign.	\$874.50	2016	May 16	Parking Commission	completed	
Parking Deck	P-007		D. Off-Street Parking Spaces	A.Total # of parking spaces B.Total # of designated accessible spaces D.Min space not provided F. Vehicle space <96" wide, access aisle <60" wide, access aisle does not adjoin accessible route	near southwest stairwell	Priority 1	Program Access	Provide 2 accessible parking spaces. Provide one van-designated space. Provide parking identification sign.	\$874.50	2016	May 16	Parking Commission	completed	
Parking Deck	P-009		D. Off-Street Parking Spaces	A.Total # of parking spaces B.Total # of designated accessible spaces D.Min space not provided J.Surface not stable, firm, and slip-resistant M.Min <60" above finished floor	near building entrance	Priority 1	Program Access	Provide 2 accessible parking spaces. Provide one van-designated space. Provide parking identification sign.	\$1,740.00	2016	May 16	Parking Commission	completed	
Parking Deck	BB-063		G. Stairway (in a Walkway)	F.Handrails not continuous where required J.Handrails do not extend 12" from stairs		Priority 1	Program Access	Provide handrail extensions on both sides of stairway	\$280.00	2016	May 16	Parking Commission	completed	
Trescott Street Parking Lot	P-010		D. Off-Street Parking Spaces	A.Total # of parking spaces B.Total # of designated accessible spaces C.Minimum number of spaces not provided D.Min space not provided M.Min <60" above finished floor	entrance near Trescott Street	Priority 3	Approach and Entrance	Regrade and restripe parking lot. Provide one van-designated space. Provide an access aisle. Provide parking identification sign.	\$1,270.00	2017		Parking Commission		
Trescott Street Parking Lot	P-011		D. Off-Street Parking Spaces	A.Total # of parking spaces B.Total # of designated accessible spaces C.Minimum number of spaces not provided D.Min space not provided M.Min <60" above finished floor	entrance near Cedar Street	Priority 3	Approach and Entrance	Provide an access aisle. Provide parking identification sign.	\$1,500.00	2017	2019	Parking Commission	completed	
Trescott Street Parking Lot	BB-064		D. Off-Street Parking Spaces	M.Min <60" above finished floor	entrance nr Main St.	Priority 3	Approach and Entrance	Provide parking identification sign.	\$262.00	2017	2018	Parking Commission	completed	
Weir Street Parking Lot	P-012		D. Off-Street Parking Spaces	M.Min <60" above finished floor A.Total # of parking spaces B.Total # of designated accessible spaces C.Minimum number of spaces not provided D.Min space not provided F.Vehicle space <96" wide	entrance near W Water Street	Priority 3	Approach and Entrance	Provide one van-accessible space. Provide an access aisle.	\$870.00	2017		Parking Commission		
									\$55,271.75					